Major Source Boiler with Natural Gas or Refinery Gas (Gas 1) Subcategory

	Capacity or Use	Oxygen Trim	Initial Notice of	Conduct an	Tune-up Frequency	Complete One-Time	Required to Meet	Compliance
	Туре	System?	Applicability	Initial Tune-up		Energy Assessment	Emission Limits	Certification Report ₁
Existing	≤ 5 MMBTU/hr	_	05/31/2013	01/31/16	Every five (5) years	01/31/16	_	01/31/17
	< 10 MMBTU/hr	Yes	05/31/2013	01/31/16	Every five (5) years	01/31/16	I	01/31/17
	< 10 MMBTU/hr	No	05/31/2013	01/31/16	Every two (2) years	01/31/16	I	01/31/17
	≥ 10 MMBTU/hr	Yes	05/31/2013	01/31/16	Every five (5) years	01/31/16	ı	01/31/17
	≥ 10 MMBTU/hr	No	05/31/2013	01/31/16	Annually	01/31/16	I	01/31/17
	Limited Use	_	05/31/2013	01/31/16	Every five (5) years	01/31/16	I	01/31/17
New	≤ 5 MMBTU/hr		within 15 days	Within 61	Every five (5) years		-	
		_	of startup	months of		_		01/31/17
				start-up				
	< 10 MMBTU/hr	Yes	within 15 days	Within 61	Every five (5) years			
			of start-up	months of		_	_	01/31/17
				start-up				
	< 10 MMBTU/hr	No	within 15 days	Within 25	Every two (2) years			
			of start-up	months of		_	_	01/31/17
				start-up				
	≥ 10 MMBTU/hr	Yes	within 15 days	Within 61	Every five (5) years			
			of start-up	months of		_	_	01/31/17
				start-up				
	≥ 10 MMBTU/hr	No	within 15 days	Within 13	Annually			
			of start-up	months of		_	_	01/31/17
				start-up				
	Limited Use	-	within 15 days	Within 61	Every five (5) years			
			of start-up	months of		_	_	01/31/17
				start-up				

The Boiler designed to burn Gas 1 subcategory includes boilers or process heaters that only burn natural gas, refinery gas, and /or other gas 1 fuels.

Other Gas 1 Fuel is defined as a gaseous fuel that is not natural gas or refinery gas and does not exceed a maximum concentration of 40 micrograms/cubic meters of mercury.

A *Limited Use* boiler is any boiler that burns any amount of solid or liquid fuel and has a federally enforceable average annual capacity factor of no more than 10%.

1. First Compliance Certification Report is due **January 31, 2017** and subsequent reports are due semi-annually, annually, biennially, or every five (5) years depending on the boiler type and capacity.